


E-Bulk

E-Bulk meter



INSTRUCTIONS FOR INSTALLATION, USE AND MAINTENANCE

Translation of the original instructions.

Before installing and using the device, please read this manual carefully and keep it with the product.

Symbols used in this manual and relative meaning



WARNING!

Indicates particularly important information.



DANGER!

Identifies actions that may lead to injury or damage to the device if not performed correctly.



PROHIBITED

Indicates actions that **MUST NOT** be performed.

Compliance

Maddalena S.p.A. declares that **E-Bulk** is compliant with the mandatory requirements of the following directives and standards:

- Directive 2014/32/EU MID (Measurement and adjustment devices)
- ISO 4064 (Water meters for cold potable water and hot water)



The full declaration of EU compliance is available from the following website: **www.maddalena.it**.

Warranty

Conditions of sale and warranty

The conditions of sale and warranty are available on the website **www.maddalena.it**.

Warranty limitations

Maddalena S.p.A. declines all responsibility, with immediate invalidation of the warranty in relation to:

- Damage or defects caused by transport or loading/unloading
- Incorrect installation caused by a failure to observe the instructions provided
- Use for purposes other than those indicated in this manual
- Use by unqualified or untrained personnel

Contents

1	General information	3
1.1	Warnings and safety rules	3
1.2	Restrictions	4
1.3	Device description	4
1.4	Usage limits	5
1.5	Structure	5
1.5.1	Dimensions	5
1.6	Identification	6
1.7	Display	6
1.7.1	Faults and errors	7
1.8	Technical specifications	8
1.9	Technical specifications radio module (optional)	9
1.10	Additional technical specifications	10
1.10.1	PLC-PNP input diagram for connecting the pulse output	10
1.10.2	Split pulse output	11
1.10.3	Pressure drop	12
1.10.4	Error curve	12
1.11	Analogue output 4-20mA (optional)	13
2	Installation	14
2.1	Receipt of the product	14
2.2	Assembly	14
3	Use	19
4	Configuration	19
5	Maintenance	21
5.1	Battery	21
5.2	Cleaning	21
5.3	Disposal	21
6	Certified and approved	22

1 General information

1.1 Warnings and safety rules



WARNINGS

- This manual is the property of **Maddalena S.p.A.** and may not be reproduced or transferred to third parties: all rights reserved. It is an integral part of the product; make sure it is always with the device, even if it is sold/transferred to another owner, so that it can be consulted by the user or by personnel authorised to carry out maintenance and repairs.
- Read this manual carefully before using the device to ensure safe operation.
- The device must be used as intended by **Maddalena S.p.A.**, which is not liable for damage caused to persons, animals or property by installation, adjustment or maintenance errors or improper use of the device.
- After unpacking, ensure the delivery is intact and complete. If it does not correspond to what was ordered, contact the local distributor who sold you the device.
- The device must be installed and used in an area protected from freezing.
- The device must be protected against extreme humidity and heat: intense weather conditions can damage the battery and the device. The maximum permissible temperature during operation is 50°C.
- If in doubt about the condition and/or functionality of the device and its parts, please contact your local distributor for further information.
- Once the device has been commissioned, report any faults or malfunctions found to the product supplier.
- In the event of complete destruction of the device, with the electrolyte escaping, avoid skin and eye contact with the electrolyte. Do not inhale the vapours produced and ventilate the room adequately.
- This device is not intended for use by persons with reduced mental or motor capacities, or lack of experience and knowledge (including children), unless they are supervised by a person responsible for their safety and given appropriate instruction on how to use the device.

1.2 Restrictions



PROHIBITED

- Make modifications and/or attempt to repair the product. Any intervention may only be carried out by authorised personnel.
- Shorten or lengthen the pulse output cable in order not to impair meter performance.
- Leave the device exposed to the weather.
- Place the device near heat sources and expose it to direct sunlight.
- Place the device close to sources of electromagnetic interference.
- Use the device in environments where the temperature drops below 0°C.
- Open the device and/or replace the battery.
- Use solvents to clean the device.
- Dispose of the packaging material in the environment and leave it within reach of children, as it can be a potential source of danger: it must be disposed of in accordance with current legislation.
- Dispose of the device with household waste.

1.3 Device description

E-Bulk is an electronic cold water meter. It measures the flow volume, flow rate and other parameter values using ultrasonic technology. The electronic meter continuously monitors the status of operating and installation parameters. In the event of a fault, it triggers the dedicated alarms.

The managed alarms are the following: circuit fault, transducer fault, and air in channel (see section “**Faults and errors**”).

The main technical specifications of the **E-Bulk** design are:


- **Liquid crystal display;**
- **Extremely low starting flow rate.** The minimum flow rate is one third that of conventional water meters. The device starts metering water at a flow rate of 10L/h;
- **Temperature detection and fault reporting.** Reporting of abnormal water consumption and ultrasonic signal quality detection;
- **Absence of moving parts.** Resistance to wear and constant functioning over time;
- **Lithium battery.** Ensures long-lasting power supply (13 years);
- **Integrated pulse output;**
- **Available with integrated 868wM-Bus radio;**
- **Available with 4-20mA output to measure the flow rate.**

1.4 Usage limits

The product can be used exclusively with diameters from DN 50 to DN 200* and with a maximum operating temperature of +50°C.


* Max DN400 on request

1.5 Structure



- 1 Cover
- 2 Display
- 3 Magnetic key door
- 4 Cable for connecting pulse reader and 4-20mA (optional)
- 5 Radio antenna (optional)
- 6 Meter housing

1.5.1 Dimensions




PN	PN10/PN16							PN10	PN16
DN (mm)	50	65	80	100	125	150	200	200	
L	200 270*	200 300*	225 300*	250 360*	250	300	350	350	
L1	120	120	120	120	123	120	120	120	
H	245	250	275	290	380	400	470	470	
H1	65	70	90	100	125	130	170	170	
W	123	123	123	123	123	123	123	123	
B	172	190	205	230	250	285	340	340	
D	165	185	200	220	250	285	340	340	
K	125	145	160	180	210	240	295	295	
n x ΦD1	4 x Φ18	4 x Φ18	8 x Φ18	8 x Φ18	8 x Φ18	8 x Φ22	8 x Φ22	8 x Φ22	

(*) Non-standard. Available on request

1.6 Identification

The **E-Bulk** meter has its identification data marked on it.




- 1 Meter label data
- 2 Production date
- 3 Battery expiration date




1.7 Display

The display shows the data on volume, flow rate and water temperature cyclically, as well as any active error codes.





Hold the magnetic key (1) close to the door (2) to change the data displayed, forcing the cyclical reading.

The segment tests on the display can also be viewed.



Description	Screenshots
Flow volume (standard display)	
Water temperature/Instant flow	
Display test	

1.7.1 Faults and errors

Faults	Screenshots
Empty tube	
The temperature of the water is low (the error message appears when the temperature is below 4°C)	
Overflow	
Errors	Screenshots
E1-11: measuring channel 1 - circuit fault	
E1-22: measuring channel 1 - faulty transducer or measuring channel or reduced flow signal	
E2-11: measuring channel 2 - circuit fault	
E2-22: measuring channel 2 - faulty transducer or air in the measuring channel or reduced flow signal	

Seals

Two seals are attached to the meter: opening the device causes them to break. Interventions must be carried out by a centre authorised by the manufacturer.

Do not alter or remove the meter seals, otherwise the warranty will be invalidated.

1.8 Technical specifications


Description	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	U.M.
Accuracy class	2							
Ratio Q3/Q1	500							
Maximum read- ing	9999999.99999				99999999.99999			m³
Maximum work- ing pressure	1.6 (1.0 upon request)							MPa
Temperature class	T50 (T30 upon request)							
Sensitivity class for installation conditions	H U0-D0, V U0-D0							
Protection class	IP68							
Power supply	3.6 lithium battery							Vcc
Useful battery life	13							years
Environmental and mechanical conditions	Class O (Class B, Class M optional)							
Electromagnetic class	MID M1, E1 (E2 on request)							
Liquid	Water							
Installation position	Any							
Overload flow Q4	31,25	50,00	78,75	125,00	200,00	312,50	500,00	m³/h
Permanent flow Q3	25,00	40,00	63,00	100,00	160,00	250,00	400,00	m³/h
Transition flow Q2	0,080	0,128	0,202	0,320	0,512	0,800	1,280	m³/h
Minimum flow Q1	0,050	0,080	0,126	0,200	0,320	0,500	0,800	m³/h
Pressure drop	25							KPa
Impulses/litres	1P=10L				1P=100L			P=L
Pulse duration	with frequency impulses generated by flow ≤4Hz 125							ms
	with frequency impulses generated by flow >4Hz half of remaining period							

1.9 Technical specifications radio module (optional)

Features	Description
Status Radio	Active (Default)
Transmitting frequency	Every 16 seconds
Encryption	Not active (Default)
Alarms	Low water temperature (<4°C), low battery level, empty tube, tampering (removal of dial), seal broken
Configuration	By radio, through the Android app and magnetic key
Power supply	Lithium-ion battery
Battery lifespan	13 years + 1 in storage
Certifications/Approvals	CE in compliance with European standards
	RED 2014/53/EU, RoHS2 (EU) 2017/2102
Standard	Wireless M-Bus, OMS (upon request)
Modes	T1 (Default), C1 (Optional)
Operating frequency range	868.0 - 868.6 / 868.7 - 869.2 MHz
Radiated power	14dBm max
Antenna gain	2dB
Antenna cable length	3m
Range	500m in line of sight
Reference standards	EN 13757
Device class	Radio class 1
Data sent	Meter serial number, total volume, instant flow, date, alarms
Environmental conditions	Storage temperature: -20°C ÷ +60°C
	Operating temperature: -10°C ÷ +50°C
Protection rating	IP68

1.10 Additional technical specifications

1.10.1 PLC-PNP input diagram for connecting the pulse output



CONNECTIONS

Conductor	Signal	Description
White	Impulses	Signal with forward and inverse flow
Yellow	Direction	Contact closed = inverse flow
Green	Tampering	Contact open = tampering
Brown	Ground	Common
Grey	Impulse counter forward	In case of inverse flow, the meter internally records the volume. When normal flow is restored, impulses are not generated until the total volume value recorded previously resets to zero.

Features	
Digital outputs (5 wires)	Impulses output, direction flow, tampering, ground, meter impulses forward
Maximum frequency of impulses	10Hz
Output type	Collector open NPN, 30Vdc, 50mAdc
Cable length	3m


1.10.2 Split pulse output

The meter has two pulse outputs which can be connected to two different devices.


First output (white wire): pulses are generated regardless of flow direction. When combined with the direction output (yellow wire) it is also possible to distinguish the direction of flow.

Second output (grey wire): compensated output. In the case of reverse flow, no pulses are generated and the measured reflux volume is compensated before the normal pulse generation is restored.


Demonstration diagram



1.10.3 Pressure drop



1.10.4 Error curve



1.11 Analogue output 4-20mA (optional)

The 4-20mA analogue output is optional and is used for measuring the flow rate.

The output current varies linearly to the flow rate between 4mA and 20mA.

The 4mA value represents the null flow rate while the 20mA value is the maximum flow rate (Q4) which varies according to the diameter of the meter.


The 4-20mA output of the **E-Bulk** is a passive circuit and must be powered by an external device not supplied to the customer.

Parameter	Value	U.M.
Power supply	24	VDC
Red wire	Positive (+)	
White wire	Ground (-)	
Cable length	3	m

The two-wire analogue output 4-20mA is separate and insulated from the 5-wire pulse output.

2 Installation

2.1 Receipt of the product



WARNING!

The instruction manual is an integral part of the device and should therefore be read and stored carefully.



PROHIBITED

Packaging material must be properly disposed of and kept out of children's reach as it may represent a hazard. Disposal must be performed in line with applicable laws.

2.2 Assembly

Authorised personnel: specialised installer or plumber, assigned by the metering operator.



WARNING!

Only authorised and suitably trained personnel with sufficient technical experience may install and operate the device.

Before installing the device, make sure that the two sections of tube are even to prevent mechanical stress, clean them with care (especially in the case of empty tubes) and let water run for a while, using a stub pipe on the tube instead of the meter.

If there is no water in the pipeline, open the valve upstream of the device before installing it. This is necessary because opening the valve after installation is complete may cause air suction that could damage the device.

Before using the meter, first fully remove air from the pipe and the device itself. The interception/adjustment valves must be fully open when doing this. Open the valve at the start first and then the valve at the end.

Install the meter:

- protected from frost (insulate it if necessary with insulation material) and in the lower part of the system to prevent air accumulation;
- protected from blows and tampering, where readings are easy to make;
- so that the direction of the arrow on the device coincides with the flow direction.

Install proper interception valves upstream and downstream of the meter to permit maintenance operations and inspections on the device, as well as to check the system.

**WARNING!**


Before positioning the seal, make sure that it is not damaged.

Make sure that the seal is not damaged during installation.



Make sure that the level of the seal matches that of the tubing.

Check that the seal does not protrude from the tube.

Make sure that the surfaces of the flange are clean and undamaged.




- Fasten the meter flange (1) to the counterflange (2) using nuts and bolts (not provided) (3). Make sure that the seal is positioned correctly and that it is level with the flange.



WARNING!

Make sure that the flange and counter-flange holes are aligned.

- Tighten the bolts.


**WARNING!**

Check the seal hold to prevent leakage.

The antenna cable (1) is fitted with a slot for a fastening screw.

Fasten the cable to a support (not provided) (2) in a vertical position as high as possible to maximize radio-signal range.

If the meter is installed underground, take the antenna out of the underground space or as close to the exit as possible. (Only for **E-Bulk** radio version).

**WARNING!**

With metallic closures on manholes, keep the antenna at least 30cm away from the metal part.




WARNING!

Sensitivity class in installation conditions: H U0-D0, V U0-D0

If the U and/or D letters are followed by the letter S, install a flow straightener.


DN50
H U0-D0



U0 = 0

D0 = 0

DN50
V U0-D0



D0 = 0

U0 = 0

3 Use

The ultrasonic water meter is ideal for significant usage and, thanks to the absence of moving parts, it is resistant to wear and grants constant functioning over time.

The measurements taken by the meter are shown cyclically on the display and they are also available on other interfaces.

- Data can be transmitted continuously using the wM-Bus 868MHz radio (optional).
- The pulse output, available as standard, allows the transmission of pulses for the metering of the water volume. Various transmission systems using different technologies can be connected to this output.
- The optional analogue output 4-20mA makes it possible to measure the flow rate: it can be connected to a local flow measurement system.

The water meter is not indicated for installations with especially heavy water, water with algae or sludge and debris.

4 Configuration

The water meter **E-Bulk** is supplied with a default configuration.

The default settings can be changed via:

- The ElecTo Bulk app (Android, downloadable from Google Play Store);
- a Bluetooth or USB optical reading head.

The app allows the following parameters to be read and programmed:



Impulse outlet



- Pulse duration (1) (default 125ms)
- Pulse weight (2) (100L per DN>100, 10L in all other cases)




General parameters

- Date and time (3)
- Periodic reading (4) (default: 28)

 **Electo Bulk**
Connected!
UniCo21804003




 **READ**
 **PROGRAM**

Synchronise clock




2021-12-09 09:39  **3**

Synchronise clock

Billing day



15   **4**



Set billing day

 Pulse counter
  Radio
  General

Internal radio parameters



- Activation / deactivation (5)
- Mode (6) (default: T1)
- Frame (7) (default: short)
- Encryption (8) (default: NO)
- Encryption key (9) (default: default)
- Transmission frequency (10) (default: 16 seconds)
- Transmission window (11) (default: 8:00-18:00)
- Transmission months (12) (default: Jan-Dec)
- Transmission days (13) (default: Mon-Fri)


 **Electo Bulk**
Connected!
UniCo21804003


 **READ**
 **PROGRAM**


Radio ON/OFF

radio transmission is active


5  

Mode  **6**


T1 **C1**

Frame  **7**


Short **Long**


Encryption  **8**


AES 128 **no encryption**


Aes key  **9**

Default **Custom AES key**


Transmission every  **10**


16 seconds 

Transmission interval  **11**


from 08:00 to 18:00 


10 hours

Transmission months  **12**



January-December 




12 months

Transmission days  **13**

Monday-Friday 

5 days

 Pulse counter
  Radio
  General

5 Maintenance

5.1 Battery

The meter is fitted with a 3.6V lithium battery that cannot be recharged but can be replaced.

The estimated lifespan of the battery is 13 years, calculated using factory set-up and with the following operating conditions:

- from -10°C to +0°C for 10% of the lifespan
- from 0°C to +30°C for 80% of the lifespan
- from +31°C to +55°C for 10% of the lifespan



WARNING!

Humidity and intense heat may damage the battery and reduce its lifespan.

The device calculates the useful remaining life of the battery based on memorized parameters, for example, estimated consumption of the electronic board in standby, consumption in transmission and the number of transmissions made.

Battery life depends on the data transmission frequency you choose to set.



DANGER!

If the battery is empty, it is necessary to contact the metering operator for the correct replacement procedure.

The battery must be disposed of in compliance with applicable laws on waste disposal in the country of installation.

5.2 Cleaning

No particular cleaning procedures are required. However, the installation area should be kept clean and periodic checks should be performed to ensure the required environmental conditions are met.



PROHIBITED

Use of abrasive products, petrol or trichloroethylene is not permitted.

5.3 Disposal

The device is made from various materials such as: metal and plastic materials, electrical and electronic components. It must be disposed of in accordance with current local regulations on industrial and special waste. It must not be disposed of with household waste.

The device does not contain any toxic/hazardous substances or elements, including lead, mercury, cadmium, hexavalent chromium, polybrominated biphenyl.

At the end of the product's life, ensure safe removal and responsible disposal of components, including recycling of batteries, in compliance with applicable environmental laws in the country of installation.



6 Certified and approved



DICHIARAZIONE DI CONFORMITÀ UE EU DECLARATION OF CONFORMITY

Modello **E-BULK (DN 50÷400 mm)**
Model

Nome e indirizzo del fabbricante **Maddalena S.p.A.**
Name and address of the manufacturer **Via G.B. Maddalena 2/4 – 33040 Povoletto (UD), Italy**

La presente dichiarazione di conformità è emessa sotto la responsabilità esclusiva del fabbricante.
This declaration of conformity is issued under the sole responsibility of the manufacturer.

Oggetto **Contatore per acqua ultrasonico**
Object **Ultrasonic water meter**

L'oggetto della dichiarazione di cui sopra è conforme alla pertinente normativa di armonizzazione dell'Unione: Direttiva 2014/32/UE, Allegato MI-001.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation: Directive 2014/32/EU, Annex MI-001.

Norme armonizzate pertinenti, documenti normativi e riferimenti alle altre specifiche tecniche utilizzate per la dichiarazione **UNI EN ISO 4064:2017**

Relevant harmonised standards and normative documents and references to other technical specifications used for declaration

Nome e numero dell'organismo notificato <i>Name and number of the notified body</i>	Attività <i>Activity</i>	Certificato nr. <i>Certificate no.</i>
Romanian Movement for Quality, NB 2275 Srt.Parului nr.8 Craiova, Doli Romania	Certificato di esame UE del tipo in accordo al Modulo B della Direttiva 2014/32/UE <i>EU-type certification in accordance with Module B of Directive 2014/32/EU</i>	RO-2275-19454
Czech Metrology Institute, NB 1383 Okružní 31 638 00 Brno Czech Republic	Certificazione di prodotti, collaudo e controlli finali in accordo al Modulo D della Direttiva 2014/32/UE <i>Certification of production, final product inspection and testing in accordance with Module D of Directive 2014/32/EU</i>	0119-SJ-A010-08

Povoletto, 09/09/2020

Maddalena S.p.A.

Dott.Ing. Franco Maddalena
IL PRESIDENTE
Legale Rappresentante
The President



MADDALENA S.p.A.
Via G.B. Maddalena, 2/4 - 33040 Povoletto (UD), Italy
Tel. +39 0432 634811
Fax +39 0432 634897
PEC: commerciale@maddalena.legalmail.it
www.maddalena.it

Capitale sociale/Share capital 2.080.000 €
C.F. e reg. impr./Tax id. and business reg. no. UD 80008170302
P.IVA/VAT no. IT00617140306
Numero REA/REA no. UD128629
Export reg. UD007790



NB 2275

Certificat de examinare UE de tip EU-type examination certificate

Număr RO-2275-19454, revizia 2
Number RO-2275-19454, revision 2

accredited for
CERTIFICATION



SR EN ISO/IEC 17065:2013
ACCREDITATION CERTIFICATE
ON 041

Eliberat de
Issued by

MIȘCAREA ROMÂNĂ PENTRU CALITATE/ ROMANIAN MOVEMENT FOR QUALITY
Parului Str., No. 8, Craiova, Dolj county, Romania
Tel: 0351/451 047; Tel/Fax: 0251/545 553; office@mrco.ro, mrco@rdscv.ro, www.mrco.ro

În conformitate cu
According to

Directiva 2014/32/UE a Parlamentului European și a Consiliului din 26 februarie 2014 privind armonizarea legislației statelor membre referitoare la punerea la dispoziție pe piață a mijloacelor de măsurare (reformare), Anexa III Contoare de apă (MI – 001), Anexa II Modulul B: Examinarea UE de tip
Directive 2014/32/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of measuring instruments (recast), Annex III – Water meters (MI-001), Annex II Module B: EU-Type Examination

Producător
Manufacturer

MADDALENA SpA.
Address: Via G.B. Maddalena 2/4, 33040, Povoletto (UD), Italy

Referitor la
Concerning to

Contor de apă tip E-BULK, seria DN 50...DN 400
Water meter E-BULK type DN 50...DN 400 series

Caracteristici
Characteristics

Clasa de temperatură/ Temperature class. T30; T50
Caracteristici descrise în Anexă/
Characteristics described in Annex

Descriere și
documentație
Description and
documentation

Mijlocul de măsurare corespunde cu cerințele Directivei 2014/32/UE și este descris în Anexă, parte integrantă din prezentul certificat.
The measuring instrument meets the requirements of Directive 2014/32/EU and it is described in Annex, a part of this certificate.

Eliberat la
Issued on

10.11.2022

Valabil până la
Valid until

11.11.2029

Organism notificat nr. 2275
Notified Body no. 2275

PhD eng. Maria-Magdalena POENARU
EXECUTIVE DIRECTOR



Certificatul fără semnătură și ștampilă nu este valabil. Prezentul certificat este valabil numai însoțit de Anexă. Certificatul are 16 pagini, inclusiv anexa.
Certificate without signature and stamp is not valid. The present certificate is valid only accompanied by Annex. The certificate has 16 pages, including the annex.



MADDALENA spa

Via G.B. Maddalena 2/4 - 33040 Povoletto (Udine)

Tel. +39 0432 634811

www.maddalena.it

Maddalena S.p.A. reserves the right to change its products at any time and without prior notice, with the aim of improving them and without compromising primary features. All the graphic illustrations and/or photographs appearing in this document can be represented with optional accessories that vary in relation to the country where the device is used.